



Renovations Check

Check
Box *

| No. | | |
|-----|--|--|
| 01 | Check all documents against site check and verification of dimensions report (D 24). Site-check any discrepancies. | |
| 02 | Check for details at all locations where new construction meets existing. | |
| 03 | Where appropriate, verify that all known services required to remain are shown on drawings. | |
| 04 | Verify that all remedial/repair work called for in complete site survey report is covered (D 25). | |
| 05 | Check for any new piping and conduit to be run in solid walls; check for sufficient furring. | |
| 06 | Verify that chases in solid walls do not go through structural beams. | |
| 07 | Verify that "make good" notes are sufficiently precise to make clear the intended scope. | |
| 08 | Verify that historic/important detail to be conserved is properly identified and protection called for. | |
| 09 | Verify structural drawings resolve all known structural deficiencies. | |
| 10 | Verify that access exists to run ducts and piping above suspended ceilings. | |
| 11 | Verify that vertical shafts on different floors actually line up. | |
| 12 | Verify that all cabinet details permit site adjustment for sloping floors, walls and ceilings. Cabinet bases to be supplied loose. | |
| 13 | Confirm continuity of any required fire separation. | |
| 14 | Check specification carefully against all restoration detail. | |
| 15 | Check hardware back sets and thickness limits against actual door stiles. | |
| 16 | Verify provision for treatment where door hardware is to be removed/replaced. | |
| 17 | Check door and window schedules for remedial work required, against each door and window on site. | |
| | | |
| | | |
| | | |
| | | |
| | | |
| | | |
| | | |
| | | |
| | | |
| | | |
| | | |
| | | |
| | | |
| | | |
| | | |
| | | |